

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 350

Dated: 18/9/2026

It is certified that an inspection team headed by

*AKSHAY Kr. Meena (JEN) (Name of Officers with designation)

from Assistant Engineer PHED CSD (JEN) Banipark PHED

inspected the Jaipur International Public School, Banipark

(Name & Address of the school) on 08-09-26 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. Lab/Bact/2026-27/1868-64

dated 16/09/26 of PHED State LAB, Gandhi Nagar (PHED Lab)

certified that the

Jaipur International Public School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 6 month.

Signature with Seal

Name

Designation

Name & Address of the Office / Department

Signature with Seal
Name : D. VANSHU KATHORE
Designation : ASSISTANT ENGINEER
Name & Address of the Office / Department : PHED
सहायक अभियन्ता
नगर उप खण्ड VI (उत्तर)
जन स्वा. अभि. विभाग
बनीपार्क जयपुर
कोड 10-024586

To

JAIPUR INTERNATIONAL
PUBLIC School Banipark

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Office of the Chief Chemist
Public Health Engineering Department, Rajasthan, Jaipur

Report of the Chemical Examination of Water

To:
Assistant Engineer,
Sub Division City- VI (N) Banipark, Jaipur,
Behind Gulabi Nagar Restaurant, Bihari Marg, Banipark.

Reference No : 329, Dated : 01/09/2026

District : JAIPUR

Date of Receipt : 01/09/2026

Sample Taker : AEn

Source	Permissible Value as per B.I.S 10500/2012		TW	Tap
Location			Adarsh Vidya Mandir School	Jaipur International Public School
Other Habitation	Desirable Limit	Permissible limit in absence of alternate Source		
Village/Town			Jaipur (M Corp.) (Part)	Jaipur (M Corp.) (Part)
Gram Panchayat				
Date of Collection			01/09/2026	01/09/2026
Date of Examination			02/09/2026	02/09/2026
Sample No			1211	1212

Note:- All results except pH are in mg/L

pH	6.5 to 8.5	No relaxation	7.70	7.84
Turbidity(NTU)	1	5	Clear	Clear
Colour	5	15	Colourless	Colourless
Odour	Agreeable	Agreeable	Smell less	Smell less
Temperature	---	---	25	25
Total Alkalinity	200	600	160	132
Total Hardness (as CaCO ₃)	200	600	300	136
Calcium (as Ca)	75	200	48	32
Magnesium (as Mg)	30	100	43.92	13.664
Chloride(as Cl)	250	1000	140	75
Sulphate(as SO ₄)	200	400	---	---
Nitrate as(NO ₃)	45	45	111.5	1.3
Fluoride	1.0	1.5	0.24	0.30
Total Dissolved Solids	500	2000	797	462
Iron	1.0	No Relaxation	---	---
Residual Chlorine	0.2	1.0	---	---

Remarks : Water is Potable (P)/Unpotable (U)
No Lab./Tech.(chem)/2026-27/1211-1212

Superintending Chemist (Heavy Metals)
PHED Laboratory, Jaipur

Copy To :
1. Chief Chemist, State Laboratory Gandhi Nagar, Jaipur

Superintending Chemist (Heavy Metals)
PHED Laboratory, Jaipur



OFFICE OF THE CHIEF CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT, STATE LABORATORY

Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015

BACTERIOLOGICAL EXAMINATION REPORT

No: Lab/Bact/2026-27/

1863-64

Dated:- 16/9/26

Assistant Engineer

Public Health Engineering Department,

Sub Division- VI (North)

Jaipur

Distt: Jaipur

Name of Sample Taker :- J En

Reference :- Lt No - 340 Dt 08/09/2026

Lab Sample No.	Date of Collection	Date of Examination	Source	Particulars of Samples	Total Coliform Organisms (MPN/100 ml)	E-Coli Organism (MPN/100ml)	Remarks (Satisfactory/ Unsatisfactory)
1275	08-09-26	08-09-26	TW	Adarsh Vidhya Mandir Sindh Colony Banipark	0	0	Satisfactory
1276	08-09-26	08-09-26	Tap	Jaipur International Public School Banipark	0	0	Satisfactory

Sent
Superintending Chemist (HM & Jaipur City)
PHED, Laboratory, Jaipur

No: Lab/Bact/2026-27/

1863-64

Dated:

16/9/26

Copy to:

1. The Chief Chemist, PHED, Rajasthan, Jaipur

Sent
Superintending Chemist (HM & Jaipur City)
PHED, Laboratory, Jaipur